

Table 1. Follow-up Legionella Water Testing Results - Performed 8/19/2020

Lane Community College - Eugene, Oregon

Various Buildings & Fixtures

Building*	Floor*	Fixture*	Location*	Type of Sample	Test Kit Serial Number	Results (MPN/100mL) ¹	Previous Results (MPN/100mL) ²
Center	1st	10	101C Doug's	First Draw	114058	4	1460
				Flush	110979	106	
		16	Student Microwave Area	First Draw	114060	ND	175
				Flush	90140	4	
	2nd	3	200G Coffee Area	First Draw	89010	2	142
				Flush	89083	ND	
		1	207 Mothering Room	First Draw	89009	ND	328
				Flush	110980	1	
	3rd	1	328 Break Room	First Draw	110976	35	422
				Flush	114061	51	
		3	311 Academic Testing	First Draw	89033	16	18
				Flush	110969	3	
	4th	1	404 Staff Lounge	First Draw	89070	ND	79
				Flush	89078	ND	
2		448 Staff Lounge	First Draw	111584	26	22	
			Flush	114078	20		
1	1st	1	126 Work Room	First Draw	114059	9	2
				Flush	110962	1	
		2	115A Work Room	First Draw	89090	9	169
				Flush	110960	18	
	2nd	1	201 Student Activities	First Draw	89092	ND	318
				Flush	89058	ND	
3	1st	1	121 HR Kitchen	First Draw	110997	92	1
				Flush	110963	205	
	2nd	1	216A Coffee Room	First Draw	114069	4	3
				Flush	111318	463	
4	2nd	1	232 Break Room	First Draw	99060	1	1
				Flush	110970	2	
5	1st	1	102	First Draw	110990	3	449
				Flush	110998	1	
		3	125	First Draw	89048	ND	1920
				Flush	110954	113	
	2nd	3	222 Lounge	First Draw	107303	ND	62
				Flush	89027	1	
7	2nd	3	222	First Draw	114067	16	47
				Flush	110985	ND	
10	1st	12	108	First Draw	110966	3	7
				Flush	110968	2	

Building*	Floor*	Fixture*	Location*	Type of Sample	Test Kit Serial Number	Results (MPN/100mL) ¹	Previous Results (MPN/100mL) ²
11	1st	1	101 Work Room	First Draw	89063	ND	2
				Flush	89001	ND	
	2nd	2	226 Staff Lounge	First Draw	89057	ND	2
				Flush	89049	ND	
12	1st	2	121 Break Room	First Draw	89062	ND	712
				Flush	110955	ND	
15	1st	1	106 Break Room	First Draw	114065	1	8
				Flush	114071	1	
16	1st	3	164 Work Room	First Draw	114072	316	134
				Flush	114056	40	
	2nd	1	205 Lunchroom	First Draw	90164	28	2
				Flush	114068	1	
		3	271	First Draw	114079	2	1
				Flush	114070	6	
17	1st	1	101 Lobby	First Draw	114062	ND	872
				Flush	114073	3	
18	1st	1	107	First Draw	114053	11	196
				Flush	114051	ND	
		24	109 Break Room	First Draw	114063	4	477
				Flush	114064	ND	
	2nd	1	205 Work Room	First Draw	114066	ND	1
				Flush	114077	1	
19	1st	16	143 Work Room	First Draw	114054	172	555
				Flush	114076	32	
	2nd	2	231H Work Room	First Draw	114055	ND	13
				Flush	114075	2	
		4	266B Lounge	First Draw	114057	1	4
				Flush	114074	ND	
30	2nd	1	243	First Draw	89022	ND	131
				Flush	110957	16	
		9	219	First Draw	110984	82	1460
				Flush	110996	44	

NOTES: * Denotes location data provided by LCC staff

¹ MPN/100mL = Most Probable Number of viable cells in cultured sample dilution per 100 milliliters of sampled water

² "Previous Results" references data collected during initial sampling event on August 5, 2020