

Building	Room Number	Description	Chlorine Result	Date
24	122	Break Room	.23 ✓	10/26/20
25	203	RR	.22 ✓	10/26/20
25	206	Child RR Rt.	.24 ✓	10/26/20
26	316	Entry	.26 ✓	10/26/20
27	408	Classroom Lft	.22 ✓	10/26/20
100	205	work Room	.24 ✓	10/26/20
116	193	SRC Lft Faucet	.21 ✓	10/26/20
00	404	Break Room	.21 ✓	10/26/20
00	311	work Room	.23 ✓	10/26/20
00	2006	Coffee Triple Sink RT	.24 ✓	10/26/20
00	101E	Pizza Faucet far RT	.26 ✓	10/26/20
25	206	Child RR Lft	.22 ✓	10/27/20
25	208	Handwashing	.23 ✓	10/27/20
30	131	workroom	.26 ✓	10/27/20
30	221	workroom	.24 ✓	10/27/20
06	211	Mop Sink	.26 ✓	10/27/20
06	109	mop sink	.21 ✓	10/27/20
07	106	Break room	.24 ✓	10/27/20
07	212	Lunchroom	.23 ✓	10/27/20
25	207	supply sink	.20 ✓	10/28/20
25	211	changing sink	.22 ✓	10/28/20
06	203	RR Sink	.21 ✓	10/28/20
06	004	RR Sink RT	.22 ✓	10/28/20
09	108	WR Sink	.25 ✓	10/28/20
01	212	Conference Room Sink	.23 ✓	10/28/20
01	115A	breakroom	.21 ✓	10/28/20
02	112	breakroom	.24 ✓	10/28/20
03	215	breakroom	.22 ✓	10/28/20
03	107A	breakroom	.25 ✓	10/28/20
04	232	Staff lounge	.21 ✓	10/28/20
04	104	Classroom Sink	.23 ✓	10/28/20
31	103	East Sink	.22 ✓	10/28/20
15	106	<del>Break</del> Sink <sup>Break</sup>	.21 ✓	10/28/20
15	201A	Kitchenette Sink	.23 ✓	10/28/20
17	101	Lobby Sink	.21 ✓	10/28/20
19	231J	Conference Sink	.24 ✓	10/28/20
19	109	NW faucet	.26 ✓	10/28/20
61	108	Classroom Sink	.51 ✓	10/29/20
61	237		.29 ✓	10/29/20
61	320A	class storage Sink	.30 ✓	10/29/20
61	407	workroom sink	.28 ✓	10/29/20
25	205	Handwashing RT	.22 ✓	10/30/20
25	206	Changing Sink	.24 ✓	10/30/20
06	002	RR Sink Lft	.23 ✓	10/30/20
06	130	MRR Sink Lft	.21 ✓	10/30/20

