

Chlorine Tests 10/14/2020

Building	Room	Result (in ppm)
16	164	0.27
16	156D	0.25
16	193	0.25
16	205	0.22
16	271	0.24
16	147	0.30
16	148	0.33
16	119	0.22
16	117	0.27
16	115	0.25
16	111	0.25
16	109	0.29
16	107	0.30
16	105	0.23
16	103	0.24
19	143	0.29
19	142	0.27
19	109 #1	0.22
19	109 #2	0.23
19	114 #1	0.27
19	114 #2	0.31
19	107	0.25
19	266B	0.30
19	244	0.33
19	231H	0.28
19	231J	0.26

October 23, 2020

Location	Fixture Number	Description	Chlorine Test Results
Hydrant	7	East Hydrant	.31
Hydrant	8	North Hydrant	.33
25/203	RR1	Restroom Sink	.24
25/208	01	Eating Area Sink	.28
25/208	02	Eating Area Sink	.26
25/206	03	Changing Area Sink	.24
25/206	RR2	Child Restroom Sink	.22
25/206	RR3	Child Restroom Sink	.22
25/207	04	Work Room Sink	.23
25/210	05	Handwashing Sink	.24
25/210	06	Changing Area Sink	.25

Building	Room Number	Description	Chlorine Result	Date
24	122	Break Room	.23	10/26/20
25	203	RR	.22	10/26/20
25	206	China RR Rt.	.24	10/26/20
26	316	Entry	.26	10/26/20
27	408	Classroom Lft	.22	10/26/20
100	205	work Room	.24	10/26/20
116	193	SRC Lft Faucet	.21	10/26/20
00	404	Break Room	.21	10/26/20
00	311	work Room	.23	10/26/20
00	2006	Coffee Triple Sink RT	.24	10/26/20
00		Pizza Faucet far RT	.26	10/26/20
25	206	Child RR Lft	.22	10/27/20
25	208	Handwashing	.23	10/27/20
30	131	workroom	.26	10/27/20
30	221	workroom	.24	10/27/20
06	211	Mop Sink	.20	10/27/20
06	109	mop sink	.21	10/27/20
07	106	Break room	.24	10/27/20
07	212	Lunchroom	.23	10/27/20
25	207	supply sink	.20	10/28/20
25	211	changing sink	.22	10/28/20
06	203	RR Sink	.21	10/28/20
06	004	RR Sink RT	.22	10/28/20
09	108	WR Sink	.25	10/28/20
01	212	Conference Room Sink	.23	10/28/20
01	115A	breakroom	.21	10/28/20
02	112	breakroom	.24	10/28/20
03	215	breakroom	.22	10/28/20
03	107A	breakroom	.25	10/28/20
04	232	Staff lounge	.21	10/28/20
04	104	Classroom Sink	.23	10/28/20
31	103	East Sink	.22	10/28/20
15	106	Break Sink Break	.21	10/28/20
15	201A	Kitchenette Sink	.23	10/28/20
17	101	Lobby Sink	.21	10/28/20
19	231J	Conference Sink	.24	10/28/20
19	109	NW faucet	.26	10/28/20
61	108	Classroom Sink	.51	10/29/20
61	237		.29	10/29/20
61	320A	Class Storage Sink	.30	10/29/20
61	407	workroom sink	.28	10/29/20
25	205	Handwashing RT	.22	10/30/20
25	206	Changing Sink	.24	10/30/20
06	002	RR Sink Lft	.23	10/30/20
06	130	MR Sink Lft	.21	10/30/20

*

